

Section 03 06 00 - Schedules for Concrete Heat Tracing for Elevated Slab Heating EasyHeat™



PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes a heat trace system for elevated concrete slab heating, consisting of heating cable, control and accessories. The system is designed to replace the heat lost through concrete flooring installed above unheated spaces.
- B. Related Sections
 - 1. Section 03 30 00 – Cast-In Place Concrete
 - 2. Section 07 24 00 – Exterior Insulation and Finish Systems
 - 3. Section 25 51 00 – Integrated Automation Control of Facility Equipment

1.2 REFERENCES

- A. National Electric Code (NEC)
- B. CSA Standard C22.1 – Canadian Electrical Code

1.3 SYSTEM DESCRIPTION

- A. System for elevated slab heating.
- B. System consists of a heating cable, thermostat and/or controller, and accessories.
[Select all that apply]

1.4 ACTION SUBMITTALS

- A. Product Data
 - 1. Heating cable data sheet
 - 2. Heating Cable Installation and Maintenance Instructions
 - 3. Control, monitor and accessory instructions **[Select all that apply]**
 - 4. Electrical Wiring Diagram of System

1.5 QUALITY ASSURANCE

- A. Manufacturers' Qualifications
 - 1. Manufacturer to show minimum of thirty (30) years of experience in manufacturing heating cables.
 - 2. Manufacturer to provide products consistent with IEEE 515.1 requirements.
- B. Installer Qualifications
 - 1. System installer shall have complete understanding of product and product literature from manufacturer or authorized representative prior to installation.
 - 2. Electrical connections shall be performed by a licensed electrician.
- C. Regulatory Requirements and Approvals
 - 1. Electrical Components, Devices, and Accessories: Listed and labelled as defined in NFPA 70 and marked for intended use.

1.6 DELIVERY, STORAGE AND HANDLING

- A. General Requirements: Deliver, store and handle products to prevent their deterioration or damage due to moisture, temperature changes, contaminates or other causes.

- B. Delivery and Acceptance Requirements: Deliver products to site in original, unopened containers or packages with intact and legible manufacturers' labels identifying the following:
 - 1. Product and Manufacturer
 - 2. Length/Quantity
 - 3. Installation and Maintenance Instructions
- C. Storage and Handling Requirements
 - 1. Store the heating cable in a clean, dry location with a temperature range -40°F to 140°F (-40°C to 60°C).
 - 2. Protect products from mechanical damage and water ingress.

1.7 WARRANTY

- A. Extended Warranty
 - 1. Manufacturer shall make available a minimum two (2) year warranty for heating cable. Provide one (1) year warranty for all heat trace controllers and thermostats.
 - 2. Contractor shall submit to owner the results of all installation tests required by the manufacturer.

PART 2 – PRODUCTS

2.1 MANUFACTURER

- A. Contract Documents are based on manufacturer and products named below to establish a standard of quality.
- B. Manufacturer
 - 1. Manufacturer shall be Emerson – EasyHeat
 - 2. Manufacturer to show minimum of thirty (30) years of experience in manufacturing heating cables.

2.2 MATERIALS

- A. Heating Cables **[Select all that apply]**
 - 1. TSR Type Heating Cable **[Select if applicable]**
 - a. Shall be TSR81J (120 VAC) or TSR82J (208 - 277 VAC). **[Select one]**
 - b. Shall be a self-regulating heater cable with a parallel circuit electric heater strip.
 - c. Shall feature an irradiation cross-linked conductive polymer core material that is extruded over the multi-stranded, tin-plated, 16-gauge copper bus wires.
 - d. The conductive core material shall increase or decrease its heat output in response to temperature changes.
 - e. Two inner thermoplastic jackets shall be extruded over and bonded to the core material for extra dielectric strength, moisture resistance, and protection from impact and abrasion damage.
 - f. A modified polyolefin over jacket shall cover the braid for added dielectric strength, moisture resistance, and protection from impact and abrasion damage.
 - 2. MI Trace Heating Cable **[Select if applicable]**
 - a. Heating cable shall be mineral insulated cable, series resistance heating cable by EasyHeat.

- b. The heating cable shall consist of solid conductors, mineral magnesium oxide (MgO) insulation and metal alloy 825 outer sheath.
 - c. The heating cable shall be factory assembled with a minimum 7-foot cold lead (unheated) length.
 - d. The heating cable shall operate voltages of 120, 208, 240, 277, 347, 480 or 600 VAC **[Select one]** without the use of transformers.
 - e. The mineral insulated cable tag shall have the following markings:
 - i. Complete heating cable model number
 - ii. Agency listings
- C. Thermostats – EasyHeat C3RC **[Select if applicable]**
- a. Shall be used for controlling heat tracing systems and offers the following features:
 - i. Can be used in ambient-sensing mode or line sensing mode.
 - ii. Voltage: 120, 208, 240 or 277 Vac
 - iii. Current: 22 Amps
 - iv. Enclosure: NEMA 3R rainproof gasketed cold-drawn steel with baked-on gray enamel
 - v. Adjustable temperature range: 0°F to +150°F (-15°C to +65°C)
 - vi. Fixed differential temperature: +6°F (+3.3°C)
 - vii. Capillary length: 10 ft (3.0 m)
 - viii. Maximum bulb temperature: +190°F (+88°C)
- D. Controller – EasyHeat EGPC **[Select if applicable]**
- 1. Shall be a micro-processor based digital controller specifically designed for wall mounted electric heat tracing applications.
 - 2. Shall provide temperature control of an individual heater segment with sensor monitoring, remote alarm contacts, and ground fault leakage detection.
 - 3. Shall offer the following features:
 - i. Ground Fault Trip function
 - A fixed 30mA trip level is provided for circuit integrity eliminating the need for separate EPD branch circuit breakers.
 - ii. Temperature Input:
 - Range: 0°C to +218°C (32°F to +425°F)
 - Accuracy: +/- 1°C
 - Repeatability: +/- 1°C
 - RTD: 100-ohm platinum, 3-wire, (lead compensated up to 20 ohms)
 - iii. Voltage Range: 100 Vac to 277 Vac
 - iv. Heater Switching
 - Configuration: Two-pole, EMR
 - Ratings: 100-277 Vac, 30A continuous (resistive load only)
 - Line Frequency: 50 or 60 Hz
 - v. Control Power
 - Power Requirement: Control power from heater voltage, 110-277 VAc, 12 VA max
 - vi. User Interface
 - Display: 4-character LCD Alphanumeric display
 - Panel Indicators:

- Actual Temp LED
- Setpoint Temp LED
- Alarm LED
- Keypad:
 - 4 buttons, glass-reinforced epoxy laminate faceplate
 - Next, Up, Down, Menu
- vii. Environment
 - Ambient Temperature: -40°C to +55°C Starting at -20°C (-4°F)
 - Conformal Coating: Boards conformal coated for hostile environments
- viii. Enclosure
 - Type: NEMA Type 4X, UV resistant polymer
 - Features: Captive cover screws
- ix. Alarm Output
 - Alarm: EMR Form C
 - Alarm Rating: EMR Version 24-277 Vac @ 2.0A Max, 12-30Vdc
 - Alarm Output: LED Indication
- x. Alarm Function
 - High Temperature Alarm
 - Low Temperature Alarm
 - Sensor Failure
 - Ground Fault Trip
- xi. User-Definable Options
 - Deadband: Adjustable 1°C to 6°C (2°F to 10°F)
 - Alarm Contacts: NO or NC operation

A. Accessory Kits – EasyHeat SRPCRG, SRMP, and/or SRME **[Select all that apply]**

1. Entry Seal Kit - EasyHeat SRPCRG
 - a. Shall be suitable for providing a watertight entry seal into a customer supplied junction box, power connection, end sealing, and in-line splicing.
 - b. Shall contain: ¾" NPT Box Adapter; Sealing Gasket, Lockout, heat shrinks.
2. Power Connection Kit - EasyHeat TSRP3
 - a. Shall be suitable for connecting up to two heating cables to customer supplied power wiring.
 - b. Shall include a junction box, universal base, box adapter, one molded silicon power termination and cable end seal with adhesive sealant, terminal blocks, pipe clamps, and associated hardware.
3. Power End Termination Kit – EasyHeat SRMP
 - a. Shall be suitable for terminating heating cables inside a junction box.
 - b. Shall contain: Five (5) molded silicone terminations and silicone adhesive.
4. End Seal Kit – EasyHeat SRME
 - a. Shall be suitable for sealing ends of heating cables inside a junction box.
 - b. Shall contain: Five (5) molded silicone end seals and silicone adhesive.

5. End Seal and Power Connection Kit – EasyHeat SRM2
 - a. Shall be suitable for sealing ends and terminating heating cables inside a junction box.
 - b. Shall contain: Two (2) molded silicone end seals, two (2) molded silicone terminations and silicone adhesive.
6. Strapping – EasyHeat PPG100
 - a. Shall be suitable for securing heating cable to underside of an exposed concrete slab.
 - b. Shall feature retention tabs every 1”.
 - c. Shall contain 75 ft of strapping per roll.

PART 3 – EXECUTION

3.1 EXAMINATION

- A. Preinstalling Testing
 1. Prior to installing heating cable an insulation resistance test shall be performed by the installing contractor to ensure integrity of heating cable as describe in the installation & maintenance manual.

3.3 INSTALLATION

- A. Acceptable Installers
 1. Subject to compliance with requirements of Contract Documents, installer shall be familiar with installing heating cables and equipment.
- B. The elevated slab heating system shall conform to all local building codes including but not limited to NFPA70, IEEE 515.1 Commercial Heat Tracing Applications.
- C. The installer shall layout heating cable per approved shop drawings.
- D. Grounding of the heat trace system shall be in accordance with section 26 05 26 “Grounding & Bonding for Electrical Systems”
- E. Connections of all electrical wiring shall be in accordance with section 26 05 19 “Low-Voltage Electrical Systems”
- F. Comply with the following manufacturer’s recommendations:
 1. EasyHeat Elevated Slab Heating Installation Instructions (14306-001).
 2. EGPC/AXPC100EGPC Controller Installation and Operating Instructions (14251-002). **[Select if applicable]**
 3. C3RC Thermostat Spec and Installation Sheet (14034-001). **[Select if applicable]**
 4. SRPCRG Entry Seal Kit Instructions (14015-001). **[Select if applicable]**
 5. SRMP Power End Termination Kit Instructions (14193-001). **[Select if applicable]**
 6. SRME End Seal Kit Instructions (14194-001). **[Select if applicable]**
 7. SRM2 End Seal and Power End Termination Kit Instructions (14270-001). **[Select if applicable]**
 8. TSRP3 Power Connection Kit Installation Instructions (14036-001).

3.4 FIELD QUALITY CONTROL

- A. Initial start-up and field testing (commissioning) of the system shall be performed by a technician per the owner’s requirements.
- B. Field Tests and Inspections in accordance with the EasyHeat Elevated Slab Heating Installation Instructions (14306-001) recorded and included in submittals to owner:
 1. The following test shall be performed before the heat cable has been installed:

- a. Continuity test on reel
 - b. Insulation resistance on reel – 2500 VDC, 20 megaohm minimum (for TSR cable) **OR** 500 VDC, 20 megaohm minimum (for MI Trace cable)
[Select all that apply]
2. The following test shall be performed after the heat cable has been installed:
- a. Continuity test
 - b. Insulation resistance – 2500 VDC, 20 megaohm minimum (for TSR cable) **OR** 500 VDC, 20 megaohm minimum (for MI Trace cable)
[Select all that apply]

3.5 MAINTENANCE

- A. Maintenance Service
 - 1. Comply with manufacturer's recommendations in the applicable Installation and Maintenance Instructions.

END OF SECTION